



OPEN
Compute Project

AT&T Open Fiber Distribution Hub Specification

Revision 0.2

Author: Earl Pope

Revision History

Revision	Date	Author	Description
0.1	December 5, 2017	Earl Pope	First Draft for Review within AT&T
0.2	December 6, 2017	Earl Pope	Increase Feeder Cable Size

Contents

Revision History	2
Licenses	3
Scope	4
Cabinet	5
Feeder Fiber Distribution Panel	6
Distribution Fiber Distribution Panel	7
Terminal Panel for Unassigned Splitter Module Pigtails	7
Splitter Module Frame	8
Splitter Module	8

Licenses

This specification is contributed under the OCP Contributor Licensing Agreement (OCP-CLA) by AT&T.

Limitations of the OCP CLA license are noted below:

All devices that may be referred to in this specification, or required to manufacture products described in this specification, will be considered referenced only, and no intellectual property rights embodied in or covering such devices shall be licensed as a result of this specification or such references. Notwithstanding anything to the contrary in the OCP-CLA, the licenses set forth therein do not apply to the intellectual property rights included in or related to the devices identified in this specification. For clarity, no patent claim that reads on such semiconductor devices will be considered a "Granted Claim" under the applicable OCP-CLA for this specification.

You can review the signed copies of the OCP-CLA for this specification on the OCP website. <http://www.opencompute.org/products/specsanddesign>

Usage of this specification is governed by the OCPHL permissive.

You can review this license at <http://www.opencompute.org/participate/legal-documents/>

Your use of this Specification may be subject to other third-party rights. THIS SPECIFICATION IS PROVIDED "AS IS." The contributors expressly disclaim any warranties (express, implied, or otherwise), including implied warranties of merchantability, non-infringement, fitness for a particular purpose, or title, related to the Specification. The entire risk as to implementing or otherwise using the Specification is assumed by the Specification implementer and user. IN NO EVENT WILL ANY PARTY BE LIABLE TO ANY OTHER PARTY FOR LOST PROFITS OR ANY FORM OF INDIRECT, SPECIAL, INCIDENTAL, OR CONSEQUENTIAL DAMAGES OF ANY CHARACTER FROM ANY CAUSES OF ACTION OF ANY KIND WITH RESPECT TO THIS SPECIFICATION OR ITS GOVERNING AGREEMENT, WHETHER BASED ON BREACH OF CONTRACT, TORT (INCLUDING NEGLIGENCE), OR OTHERWISE, AND WHETHER OR NOT THE OTHER PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGE.

Scope

This document defines the technical specifications for the AT&T Open Fiber Distribution Hub (FDH) that will be used in the Optical Distribution Network (ODN) for Passive Optical Networks (PON).

FDHs are commonly deployed in the ODN of PONs. The FDH: terminates the feeder fiber cables from the Telco Central Office (CO); terminates the distribution fiber cables passing customer locations in the neighborhood; houses optical splitter modules, and provides the necessary fiber routing structures and frames to provide fiber connectivity from the feeder fiber cable to the optical splitter to the distribution fiber cable(s).

The Open FDH design will include:

- Outdoor versions for pole and pad mount.
- Indoor versions for rack and wall mount.
- The cabinet will include an EIA standard 19" rail system to support the following modules:
 - Feeder Fiber Cable Termination Panel
 - Distribution Fiber Cable Termination Panel
 - Termination Panel for unassigned Splitter Module "pigtailed"
 - "Pass through" functionality (which allows bypassing the optical splitter when connectivity is required for point to point systems) will be achieved by placing a fiber jumper from any Feeder Fiber Termination Panel port to any Distribution Fiber Termination Panel port
 - Splitter Module Frame to house optical splitter modules
- The cabinet housing functionality will include:
 - Fiber Management functionality
 - Bonding and grounding requirements
 - Door or doors for front access
 - Door or removable panel for rear access

Important FDH size dimensions include:

- Feeder Fiber Termination capacity
- Distribution Fiber Termination capacity
- Termination capacity for unassigned Splitter Module "pigtailed"
- Number of Splitter Modules that can be housed in the Splitter Module Frame
- Maximum height of the cabinet

The dimensioning of an FDH is typically described by the Distribution Fiber Termination capacity. For example, an FDH 864 would be able to terminate 864 distribution fiber strands. This specification will include three FDH sizes: Large FDH (supporting 864 distribution fiber strands); Medium FDH (supporting 432 distribution fiber strands); and, Small FDH (supporting 288 distribution fiber strands).

The architecture of the Open FDH is shown in Figure 1.




Figure 1 – High Level Architecture of Open FDH

Cabinet

The cabinet is the housing and supporting structure for all other components (e.g. Feeder Fiber Cable Termination Panel, Distribution Fiber Cable Termination Panel, Termination Panel for unassigned Splitter Module “pigtails”, Splitter Module Frame) of the FDH.

Pad mount outdoor cabinets, pole mount outdoor cabinets, wall mount indoor cabinets, and indoor racks are required in three sizes: Large, Medium, and Small. Cabinets must not exceed the following maximums heights: Large 72”; Medium 40”; and, Small 34”.

Cabinets and indoor frames will utilize EIA standard 19" racks to facilitate a modular design for adding PFP functionality (e.g. Feeder Fiber Termination Panels, Distribution Fiber Termination Panels, Splitter Modules Frames).

The cabinet must accommodate #6 solid ground wire equipped with #6 compression ring lug for the cabinet. Each incoming and outgoing cable must be separately grounded to a bus bar using stranded #6 equipped with a ground lug.

Cabinet/pad combination must withstand 150 mph wind without turning over per most current version of GR-487.

Where applicable, outdoor pad mount and pole mount cabinets shall meet the criteria in the most current published version of:

- GR-3125 Outdoor Fiber Distribution Hubs
- GR-2898 Generic Requirements for Fiber Demarcation Boxes
- GR-487 Generic Requirements for Electronic Equipment Cabinets
- GR-63 NEBS Requirements for Physical Protection
- GR-326 Generic Requirements for Single Mode Optical Connectors and Jumper Assemblies
- GR-1209 Generic Requirements for Passive Optic Components
- GR-1221 Generic Reliability Assurance Requirements for Passive Optic Components

Where applicable, indoor wall mount cabinets and indoor racks shall meet the criteria in the most current published version of:

- GR-63 NEBS Requirements for Physical Protection
- GR-449 Generic Requirements and Design Considerations for Fiber Distributing Frames
- GR-3123 Generic Requirements for Indoor Fiber Distribution Hubs
- GR-326 Generic Requirements for Single Mode Optical Connectors and Jumper Assemblies
- GR-1209 Generic Requirements for Passive Optic Components
- GR-1221 Generic Reliability Assurance Requirements for Passive Optic Components

Feeder Fiber Distribution Panel

The modular Feeder Fiber Termination Panel shall be designed to mount in 19" racks in the FDH cabinets and indoor racks. The Feeder Fiber cable strands will be terminated to the panel such that access to the fiber strands are via an SC/APC (Angle Polish Connector) adapter incorporated into the panel. Versions of the Feeder Fiber Termination Panel with and without pre-terminated fiber cable tails are required. The fiber cables will be a ribbon type cable. Armored cables are required for pad mount cabinets, dielectric cables are required for pole mount cabinets, and interior OFNR with riser cable stubs are required for indoor PFPs. Two stubs lengths must be available: 50 meters and 100 meters. The number of feeder fiber terminations required for each FDH size are: Large 288 fiber strands; Medium 144 fiber strands; and, Small 72 fiber strands.

Where applicable, Feeder Fiber Distribution Panels shall meet the criteria in the most current published version of:

- GR-3125 Outdoor Fiber Distribution Hubs
- GR-2898 Generic Requirements for Fiber Demarcation Boxes
- GR-487 Generic Requirements for Electronic Equipment Cabinets

- GR-63 NEBS Requirements for Physical Protection
- GR-449 Generic Requirements and Design Considerations for Fiber Distributing Frames
- GR-3123 Generic Requirements for Indoor Fiber Distribution Hubs
- GR-326 Generic Requirements for Single Mode Optical Connectors and Jumper Assemblies
- GR-1209 Generic Requirements for Passive Optic Components
- GR-1221 Generic Reliability Assurance Requirements for Passive Optic Components

Distribution Fiber Distribution Panel

The modular Distribution Fiber Termination Panel shall be designed to mount in 19" racks in the FDH cabinets and indoor racks. The Distribution Fiber cable strands will be terminated to the panel such that access to the fiber strands are via an SC/APC adapter incorporated into the panel. Versions of the Distribution Fiber Termination Panel with and without pre-terminated fiber cable tails are required. The fiber cables will be a ribbon type cable. Armored cables are required for pad mount cabinets, dielectric cables are required for pole mount cabinets, and interior OFNR with riser cable stubs are required for indoor PFPs. Two stubs lengths must be available: 50 meters and 100 meters. The number of feeder fiber terminations required for each FDH size are: Large 864 fiber strands; Medium 432 fiber strands; and, Small 288 fiber strands.

Where applicable, Distribution Fiber Distribution Panels shall meet the criteria in the most current published version of:

- GR-3125 Outdoor Fiber Distribution Hubs
- GR-2898 Generic Requirements for Fiber Demarcation Boxes
- GR-487 Generic Requirements for Electronic Equipment Cabinets
- GR-63 NEBS Requirements for Physical Protection
- GR-449 Generic Requirements and Design Considerations for Fiber Distributing Frames
- GR-3123 Generic Requirements for Indoor Fiber Distribution Hubs
- GR-326 Generic Requirements for Single Mode Optical Connectors and Jumper Assemblies
- GR-1209 Generic Requirements for Passive Optic Components
- GR-1221 Generic Reliability Assurance Requirements for Passive Optic Components

Terminal Panel for Unassigned Splitter Module Pigtails

The modular Termination Panel for Unassigned Splitter Module Pigtails shall be designed to mount in 19" racks in the FDH cabinets and indoor racks. The panel requires an SC/APC adapter incorporated into the panel for each pigtail termination; 144 pigtail terminations required for each FDH size.

Where applicable, Distribution Fiber Distribution Panels shall meet the criteria in the most current published version of:

- GR-3125 Outdoor Fiber Distribution Hubs
- GR-2898 Generic Requirements for Fiber Demarcation Boxes
- GR-487 Generic Requirements for Electronic Equipment Cabinets
- GR-63 NEBS Requirements for Physical Protection
- GR-449 Generic Requirements and Design Considerations for Fiber Distributing Frames
- GR-3123 Generic Requirements for Indoor Fiber Distribution Hubs
- GR-326 Generic Requirements for Single Mode Optical Connectors and Jumper Assemblies
- GR-1209 Generic Requirements for Passive Optic Components
- GR-1221 Generic Reliability Assurance Requirements for Passive Optic Components

Splitter Module Frame

The Splitter Module Frame shall be designed to mount in 19" racks in the FDH cabinets and indoor racks. The Splitter Module Frame will house Splitter Modules with an 118 mm LGX form factor. The number of splitter module frames required for each FDH size are: Large 3 splitter module frames; Medium 2 splitter module frames; and, Small 1 splitter module frame.

Splitter Module

The splitter module houses the Optical Splitter Chip in a 118 mm LGX form factor. The splitter modules will be slotted in the Splitter Module Frame. The splitter module shall utilize pigtails with SC/APC connectors for both the feeder side (input port) connection and the distribution side (output ports) connections. All pigtails shall be front access (i.e. routed through the faceplate of the LGX compatible module).

Four types of splitter modules are required: 1x8; 1x16; 1x32; and, 1x64. For 1x8 and 1x16 splitters, two optical chips and associated pigtails can be housed in a single 118 mm LGX module (i.e. two optical splitters per form factor). For 1x32 splitters, one optical chip and associated pigtails can be housed in a single 118 mm LGX module. For 1x64 splitters, a double wide 118 mm LGX form factor is required to house one optical chip and associated pigtails.

The Splitter Module optics and form factor shall conform to the following:

- The wavelength bandpass of the splitter module optics shall be 1260 nm to 1650 nm.
- The 1x8 splitter module maximum insertion loss with connectors must be less than or equal to 11.3 dB.

- The 1x16 splitter module maximum insertion loss with connectors must be less than or equal to 14.3 dB.
- The 1x32 splitter module maximum insertion loss with connectors must be less than or equal to 17.6 dB.
- The 1x64 splitter module maximum insertion loss with connectors must be less than or equal to 21.2 dB.
- Splitter uniformity shall be less than or equal to 1.8 dB.
- The directivity of the device shall be less than or equal to -55 dB.
- Splitter return loss shall be less than or equal to -55 dB.
- The polarization dependent loss shall be less than or equal to 0.4 dB.
- Each device will be marked with the supplier name, a unique serial number with barcode, the CLEI code, and a vendor defined component identification code.
- The device must comply with latest version of GR-1209-CORE Passive Optical Compliant Testing.
- The device shall remain functional within a temperature range of -40° C to +70° C and a relative humidity range of 5% to 95%.
- The device must comply with latest version of GR-326-CORE Generic Requirements for Single-Mode Optical Connectors and Jumper Assemblies.